

Mike Dignacco

From: Matt Deister <mdeister@alternatedesignsinc.com>
Sent: Thursday, October 30, 2014 2:42 PM
To: Mike Dignacco; 'Chris Howard Amenia Fire Chief'
Cc: Juan Torres
Subject: RE: Hydrant approval
Attachments: 20141030_131648.pdf

Good Afternoon,

Chris and myself spoke today in reference to the hydrants, we have no issues using the Mueller Super Centurion 250.

If possible as an added bonus it would be great to order the hydrants with the 5 inch storz connection on the front, it's not the end of the world if we cant.

The storz connection is equipped on all of our 5 inch supply line hose as well as all other mutual aid agencies that would be called into help.

If the storz connection can't happen due to aesthetics of the hydrant then the normal cap is ok.

Please let us know your thoughts on this.

Just for our info all of the water mains throughout the community are going to be 6 inch correct ? The chart to the right of the hydrant detail is just showing what size taps from the 6 inch water main go to the building for fire suppression (sprinkler system) whether it be 6" or 4" correct ?

Thanks

Matt

Matt Deister
Cell: 914-804-4523
MDeister@AlternateDesignsInc.Com



2 West Road
South Salem, NY 10590
914-763-3711

From: Mike Dignacco [mailto:mdignacco@stoneleafpartners.com]
Sent: Wednesday, October 29, 2014 5:37 PM
To: Chris Howard Amenia Fire Chief (ameniafirecompany@yahoo.com)
Cc: Juan Torres; Matt Deister
Subject: Hydrant approval

Chris and Matt,

Julie, the town engineer, has requested you approve the proposed fire hydrant for use at Silo Ridge. Attached is the hydrant drawing. Please review and let me know if you approve or disapprove of this hydrant or if you need further information. Thank you.